

GENERAL REQUIREMENTS FOR UNDERGROUND TANK INSTALLATIONS

1. All relevant S.A.B.S. Codes of practice to be adhered to.
2. Provide this department with certificates for each tank to be installed.
3. Symbolic “**NO SMOKING**” signs to be displayed at pumps.
4. Provide 1 x 9kg dry chemical powder extinguisher for each pump.
5. Extinguisher to be within 23m from any pump.
6. Installation to be registered with this department and permit to be renewed annually.
7. Representative of this department to be present for (MUST be notified 24hours prior to) the following:
 - (a) Excavations are completed.
 - (b) Tanks are ready to be installed
 - (c) Installations are ready to be pressure tested
 - (d) Installations are complete
8. Provide master circuit breaker switch, remote from the pump, to isolate electricity supply to the pump in the case of an emergency.
9. Provide a notice above the “**MASTER CIRCUIT BREAKER**” in 60mm letters in both official languages to read “**EMERGENCY – PUMP SWITCHES**” in black letters on a yellow background.
10. Plans to be submitted to this department for the proposed installation.
11. No flammable liquid allowed in any tank until such time a flammable liquid permit is issued for the installation by this department.